eurobodalla shire council

Anniversary Date: Published Date: 1-Apr-24 9-Oct-24

Licensee: Eurobodalla Shire Council
EPL No.: 1398

Premises: Narooma Sewage Treatment Plant Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-24 to 31-Mar-25

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Required Month:

Sep-24

Licen	ce Point 1 - Discharge to Wat	ters - Point 1 Concentration Lin	nits	
Parameters	Unit of Measure	90 percentile concentration limit	100 percentile concentration limit	
Biological Oxygen Demand	(mg/L)	10	15	i
Oil and Grease	(mg/L)	5	10	See Note
pH	(pH Units)	-	6.5-8.5	į
Total Suspended Solids	(mg/L)	15	25	ı
Chlorophyll a	(mg/m3)			İ
Faecal Coliforms	(CFU/100mL)	200	600	İ
Total Nitrogen	(mg/L)	15	20	
Total Phosphorus	(mg/L)	8	10	1
Ammonia	(mg/L)	2	5	ı

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Point 1 as described in Condition L3.

	Licence Point 3 - Effluent Quality Monitoring (Monthly Results)								
Sample Frequency	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	
Sampling Method	Composite Sample	Grab Sample	Grab Sample	Composite Sample	Grab Sample	Composite Sample	Composite Sample	Grab Sample	
Sampled Date	Biological Oxygen Demand	Oil and Grease	pН	Total Suspended Solids	Chlorophyll a	Total Nitrogen	Total Phosphorus	Ammonia	Obtained Date
Samplea Bate	(mg/L)	(mg/L)	(pH Units)	(mg/L)	(mg/m3)	(mg/L)	(mg/L)	(mg/L)	Obtained Date
3-Sep-24	2.00	<5	7.80	5.00	4.00	3.66	7.38	0.22	13-Sep-24
100 Percentile Exceedance?	NO	NO	NO	NO	NO	NO	NO	NO	

	Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)							
Year to Date	Biological Oxygen Demand	Oil and Grease	pН	Total Suspended Solids	Chlorophyll a	Total Nitrogen	Total Phosphorus	Ammonia
real to Date	(mg/L)	(mg/L)	(pH Units)	(mg/L)	(mg/m3)	(mg/L)	(mg/L)	(mg/L)
Samples	6	6	6	6	6	6	6	6
Min	<2	<5	7.10	<2	2.50	3.66	3.660	0.14
Mean	1.33	2.50	7.52	5.83	3.52	9.36	5.403	0.71
Median (50th %ile)	1.00	2.50	7.50	6.50	3.65	9.66	4.990	0.51
90th %ile	2.00	2.50	7.80	9.50	4.35	12.95	7.140	1.43
Max (100th %ile)	2.00	<5	7.80	10.00	4.70	14.10	7.380	1.84

Licensee: Eurobodalla Shire Council

EPL No.: 1398

Premises: Narooma Sewage Treatment Plant Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-24 to 31-Mar-25

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

	Licence Point 2 - Influer	nt Volume Monitoring	
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	20000
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall	Plant Inflow	Exceedance
Sample Date	(mm)	(kL)	(YES/NO)
1-Sep-24	0	1367.6	NO
2-Sep-24	0	1291.9	NO
3-Sep-24	0	1314.5	NO
4-Sep-24	0	1312.0	NO
5-Sep-24	0	1263.0	NO
6-Sep-24	0	1315.1	NO
7-Sep-24	2.4	1297.8	NO
8-Sep-24	0	1387.5	NO
9-Sep-24	0	1333.1	NO
10-Sep-24	0	1314.8	NO
11-Sep-24	0	1304.8	NO
12-Sep-24	1	1238.4	NO
13-Sep-24	0	1343.0	NO
14-Sep-24	4.2	1345.5	NO
15-Sep-24	0	1337.9	NO
16-Sep-24	0	1389.1	NO
17-Sep-24	0	1307.7	NO
18-Sep-24	0	1318.2	NO
19-Sep-24	0	1295.8	NO
20-Sep-24	0	1359.4	NO
21-Sep-24	0	1429.0	NO
22-Sep-24	0	1436.5	NO
23-Sep-24	0	1422.3	NO
24-Sep-24	0	1382.8	NO
25-Sep-24	11.2	1462.7	NO
26-Sep-24	12	1678.5	NO
27-Sep-24	0	1497.0	NO
28-Sep-24	0	1516.4	NO
29-Sep-24	0	1498.3	NO
30-Sep-24	0	1463.2	NO
Monthly Total	30.80	41223.93	·
Monthly Minimum	0.00	1238.40	
Monthly Mean	1.03	1374.13	
Monthly Maximum	12.00	1678.54	
Year to Date Total	529.90	336663.22	<del></del>
Year to Date Minimum	0.00	1238.40	
Year to Date Mean	2.90	1839.69	
Year to Date Maximum	80.60	10775.24	



Anniversary Date: Published Date: 1-Apr-24 9-Oct-24

Licensee: Eurobodalla Shire Council

EPL No.: 1398

Premises: Narooma Sewage Treatment Plant Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-24 to 31-Mar-25

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Licence Point 3 - E	Licence Point 3 - Effluent Quality Monitoring (Monthly Results)				
Frequency	Special Frequency 2*				
Sampling Method	Grab Sample				
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date			

Licence Point 4 -	Ambient Water Monitoring	(Monthly Results)
Frequency Sampling Method	Special Frequency 2* Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date

* Special Frequency	2. at least weekly	during	the months of Nov	emher Decembe	r lanuary	February and Mai	rch

Licence Point 3 - Eff	Licence Point 3 - Effluent Quality Monitoring (Year to Date Results)				
Year to Date	Faecal Coliforms				
rear to Date	(CFU/100mL)				
Samples					
Min					
Mean					
Median (50th %ile)					
90th %ile					
Max (100th %ile)					

Licence Point 4 - A	Licence Point 4 - Ambient Water Monitoring (Year to Date Results)				
Year to Date	Faecal Coliforms				
Tear to Date	(CFU/100mL)				
Samples					
Min					
Mean					
Median (50th %ile)					
90th %ile					
Max (100th %ile)	i				

Licence Point 5 - Ambient Water Monitoring (Monthly Results)				
Frequency	Special Frequency 2*			
Sampling Method	Grab Sample			
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date		

Anniversary Date:

Published Date:

1-Apr-24

9-Oct-24

eurobodalla shire council

Licence Point 5 - A	Licence Point 5 - Ambient Water Monitoring (Year to Date Results)				
Year to Date	Faecal Coliforms (CFU/100mL)				
Samples Min Mean					
Median (50th %ile) 90th %ile May (100th %ile)					

	Monthly Exceedance Report					
Date	Exceedance Type	Parameter	Description / Action			
1	1					

Licensee: Eurobodalla Shire Council

EPL No.: 1398

Premises: Narooma Sewage Treatment Plant

Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-24 to 31-Mar-25

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/



Anniversary Date: Published Date: 1-Apr-24 9-Oct-24

